

**ARTICLE II**  
**Stormwater Management**  
**[Added 9-25-2007 by Ord. No. 36-07; amended 1-22-2008 by Ord. No. 2-08;**  
**5-12-2009 by Ord. No. 6-09]**

**§ 300-23. Scope and purpose.**

**A. Policy statement.**

- (1) It is hereby determined that the waterways within the City of Long Branch are at times subjected to flooding, that such flooding is a danger to the lives and property of the public; that such flooding is also a danger to the natural resources of the City of Long Branch, the county and the state; that development tends to accentuate flooding by increasing stormwater runoff, due to alteration of the hydrologic response of the watershed in changing from the undeveloped to the developed condition; that such increased flooding produced by the development of real property contributes increased quantities of waterborne pollutants, and tends to increase channel erosion; that such increased flooding, increased erosion, and increased pollution constitutes deterioration of the water resources of the City of Long Branch, the county and the state; and that such increased flooding, increased erosion and increased pollution can be controlled to some extent by the regulation of stormwater runoff from such development.
- (2) It is therefore determined that it is in the public interest to regulate the development of real property and to establish standards to regulate the additional discharge of stormwater runoff from such developments as provided in this chapter. Flood control, groundwater recharge, and pollutant reduction shall be achieved through the use of stormwater management measures, including green infrastructure best management practices (GI BMPs) and nonstructural stormwater management strategies. GI BMPs and low-impact development (LID) should be utilized to meet the goal of maintaining natural hydrology to reduce stormwater runoff volume, reduce erosion, encourage infiltration and groundwater recharge, and reduce pollution. GI BMPs and LID should be developed based upon physical site conditions and the origin, nature and the anticipated quantity, or amount, of potential pollutants. Multiple stormwater management BMPs may be necessary to achieve the established performance standards for water quality, quantity, and groundwater recharge. **[Amended 2-10-2021 by Ord. No. 4-21]**

**B. Purpose.** It is the purpose of this article to establish minimum stormwater management requirements and controls for major development, as defined in § 300-24.

**C. Applicability.**

- (1) This article shall be applicable to all site plans and subdivisions for the following major developments that require preliminary or final site plan or

subdivision review:

- (a) Nonresidential major developments; and
- (b) Aspects of residential major developments that are not preempted by the Residential Site Improvement Standards at N.J.A.C. 5:21, including water quantity requirements for projects that meet the definition of "major development" under this article, but do not ultimately disturb more than one acre of land as permitted pursuant to N.J.A.C. 5:21-7.1(a). **[Amended 2-10-2021 by Ord. No. 4-21]**

(2) This article shall also be applicable to all major developments undertaken by the City of Long Branch.

D. Compatibility with other permit and ordinance requirements. Development approvals issued for subdivisions and site plans pursuant to this article are to be considered an integral part of development approvals under the subdivision and site plan review process and do not relieve the applicant of the responsibility to secure required permits or approvals for activities regulated by any other applicable code, rule, act, or ordinance. In their interpretation and application, the provisions of this article shall be held to be the minimum requirements for the promotion of the public health, safety, and general welfare. This article is not intended to interfere with, abrogate, or annul any other ordinances, rule or regulation, statute, or other provision of law except that, where any provision of this article imposes restrictions different from those imposed by any other ordinance, rule or regulation, or other provision of law, the more restrictive provisions or higher standards shall control.

#### **§ 300-24. Definitions.**

Unless specifically defined below, words or phrases used in this article shall be interpreted so as to give them the meaning they have in common usage and to give this article its most reasonable application. The definitions below are the same as or based on the corresponding definitions in the Stormwater Management Rules at N.J.A.C. 7:8-1.2.

**CAFRA CENTERS, CORES OR NODES** — Those areas within boundaries incorporated by reference or revised by the Department in accordance with N.J.A.C. 7:7-13.16. **[Amended 2-10-2021 by Ord. No. 4-21]**

**CAFRA PLANNING MAP** — The map used by the Department to identify the location of Coastal Planning Areas, CAFRA centers, CAFRA cores, and CAFRA nodes. The CAFRA planning map is available on the Department's geographic information system (GIS). **[Amended 2-10-2021 by Ord. No. 4-21]**

**COMMUNITY BASIN** — An infiltration system, sand filter designed to infiltrate, standard constructed wetland, or wet pond, established in accordance with N.J.A.C. 7:8-4.2(c)14, that is designed and constructed in accordance with the New Jersey Stormwater Best Management Practices Manual, or an alternate design, approved in accordance with N.J.A.C. 7:8-5.2(g), for an infiltration system, sand filter designed to infiltrate, standard constructed wetland, or wet pond and that complies with the requirements of this article. **[Added 2-10-2021 by Ord. No. 4-21]**

**COMPACTION** — The increase in soil bulk density.

**CONTRIBUTARY DRAINAGE AREA** — The area from which stormwater runoff drains to a stormwater management measure, not including the area of the stormwater management measure itself.**[Added 2-10-2021 by Ord. No. 4-21]**

**CORE** — A pedestrian-oriented area of commercial and civic uses serving the surrounding municipality, generally including housing and access to public transportation.

**COUNTY REVIEW AGENCY** — An agency designated by the Board of County Commissioners to review municipal stormwater management plans and implementing ordinance(s). The county review agency may either be:**[Amended 2-10-2021 by Ord. No. 4-21]**

- A. A county planning agency; or
- B. A county water resource association created under N.J.S.A. 58:16A-55.5, if the ordinance or resolution delegates authority to approve, conditionally approve, or disapprove municipal stormwater management plans and implementing ordinances.

**DEPARTMENT** — The New Jersey Department of Environmental Protection.

**DESIGNATED CENTER** — A State Development and Redevelopment Plan Center as designated by the State Planning Commission such as urban, regional, town, village, or hamlet.

**DESIGN ENGINEER** — A person professionally qualified and duly licensed in New Jersey to perform engineering services that may include, but not necessarily be limited to, development of project requirements, creation and development of project design and preparation of drawings and specifications.

**DEVELOPMENT** — The division of a parcel of land into two or more parcels, the construction, reconstruction, conversion, structural alteration, relocation or enlargement of any building or structure, any mining excavation or landfill, and any use or change in the use of any building or other structure, or land or extension of use of land, by any person, for which permission is required under the Municipal Land Use Law, N.J.S.A. 40:55D-1 et seq. In the case of development of agricultural lands, "development" means any activity that requires a state permit; any activity reviewed by the County Agricultural Board (CAB) and the State Agricultural Development Committee (SADC), and municipal review of any activity not exempted by the Right to Farm Act, N.J.S.A. 4:1C-1 et seq.

**DISTURBANCE** — The placement or reconstruction of impervious surface or motor vehicle surface, or exposure and/or movement of soil or bedrock or clearing, cutting, or removing of vegetation. Milling and repaving is not considered disturbance for the purposes of this definition.**[Added 2-10-2021 by Ord. No. 4-21]**

**DRAINAGE AREA** — A geographic area within which stormwater, sediments, or dissolved materials drain to a particular receiving water body or to a particular point along a receiving water body.

**EMPOWERMENT NEIGHBORHOOD** — A neighborhood designated by the Urban

Coordinating Council in consultation and conjunction with the New Jersey Redevelopment Authority pursuant to N.J.S.A. 55:19-69.

**ENVIRONMENTALLY CONSTRAINED AREA** — The following areas where the physical alteration of the land is in some way restricted, either through regulation, easement, deed restriction or ownership, such as wetlands, floodplains, threatened and endangered species sites or designated habitats, and parks and preserves. Habitats of endangered or threatened species are identified using the Department's Landscape Project as approved by the Department's Endangered and Nongame Species Program.**[Added 2-10-2021 by Ord. No. 4-21]**

**ENVIRONMENTALLY CRITICAL AREA** — An area or feature which is of significant environmental value, including, but not limited to: stream corridors; natural heritage priority sites; habitats of endangered or threatened species; large areas of contiguous open space or upland forest; steep slopes; and wellhead protection and groundwater recharge areas. Habitats of endangered or threatened species are identified using the Department's Landscape Project as approved by the Department's Endangered and Nongame Species Program.

**EROSION** — The detachment and movement of soil or rock fragments by water, wind, ice or gravity.

**GREEN INFRASTRUCTURE** — A stormwater management measure that manages stormwater close to its source by:**[Added 2-10-2021 by Ord. No. 4-21]**

- A. Treating stormwater runoff through infiltration into subsoil;
- B. Treating stormwater runoff through filtration by vegetation or soil; or
- C. Storing stormwater runoff for reuse.

**HYDROLOGIC UNIT CODE 14 (HUC 14)** — An area within which water drains to a particular receiving surface water body, also known as a subwatershed, which is identified by a fourteen-digit hydrologic unit boundary designation, delineated within New Jersey by the United States Geological Survey.**[Added 2-10-2021 by Ord. No. 4-21]**

**IMPERVIOUS SURFACE** — A surface that has been covered with a layer of material so that it is highly resistant to infiltration by water.

**INFILTRATION** — The process by which water seeps into the soil from precipitation.

**LEAD PLANNING AGENCY** — One or more public entities having stormwater management planning authority designated by the regional stormwater management planning committee, pursuant to N.J.A.C. 7:8-3.2, that serves as the primary representative of the committee.**[Added 2-10-2021 by Ord. No. 4-21]**

**MAJOR DEVELOPMENT****[Amended 2-10-2021 by Ord. No. 4-21]** —

- A. An individual development, as well as multiple developments that individually or collectively result in:
  - (1) The disturbance of 1/2 acre or more of land since February 2, 2004;

- (2) The creation of 1/4 acre or more of regulated impervious surface since February 2, 2004;
- (3) The creation of 1/4 acre or more of regulated motor vehicle surface since March 2, 2021; or
- (4) A combination of Subsection A(2) and (3) above that totals an area of 1/4 acre or more. The same surface shall not be counted twice when determining if the combination area equals 1/4 acre or more.

B. Major development includes all developments that are part of a common plan of development or sale (for example, phased residential development) that collectively or individually meet any one or more of Subsection A(1), (2), (3) or (4) above. Projects undertaken by any government agency that otherwise meet the definition of "major development" but which do not require approval under the Municipal Land Use Law, N.J.S.A. 40:55D-1 et seq., are also considered major development.

**MOTOR VEHICLE** — A land vehicle propelled other than by muscular power, such as automobiles, motorcycles, autocycles, and low-speed vehicles. For the purposes of this definition, motor vehicle does not include farm equipment, snowmobiles, all-terrain vehicles, motorized wheelchairs, go-carts, gas buggies, golf carts, ski-slope grooming machines, or vehicles that run only on rails or tracks. **[Added 2-10-2021 by Ord. No. 4-21]**

**MOTOR VEHICLE SURFACE** — Any pervious or impervious surface that is intended to be used by motor vehicles and/or aircraft and is directly exposed to precipitation, including, but not limited to, driveways, parking areas, parking garages, roads, racetracks, and runways. **[Added 2-10-2021 by Ord. No. 4-21]**

**MUNICIPALITY** — The City of Long Branch.

**NEW JERSEY STORMWATER BEST MANAGEMENT PRACTICES (BMP) MANUAL** — The manual maintained by the Department providing, in part, design specifications, removal rates, calculation methods, and soil testing procedures approved by the Department as being capable of contributing to the achievement of the stormwater management standards specified in this article. The BMP Manual is periodically amended by the Department, as necessary, to provide design specifications on additional best management practices and new information on already included practices reflecting the best available current information regarding the particular practice and the Department's determination as to the ability of that best management practice to contribute to compliance with the standards contained in this article. Alternative stormwater management measures, removal rates, or calculation methods may be utilized, subject to any limitations specified in this article, provided the design engineer demonstrates to the municipality, in accordance with § 300-26F of this article and N.J.A.C. 7:8-5.2(g), that the proposed measure and its design will contribute to achievement of the design and performance standards established by this article. **[Added 2-10-2021 by Ord. No. 4-21]**

**NODE** — An area designated by the State Planning Commission concentrating facilities and activities which are not organized in a compact form.

**NUTRIENT** — A chemical element or compound, such as nitrogen or phosphorus, which is essential to and promotes the development of organisms.

**PERSON** — Any individual, corporation, company, partnership, firm, association, the City of Long Branch, or political subdivision of this state subject to municipal jurisdiction pursuant to the Municipal Land Use Law, N.J.S.A. 40:55D-1 et seq.

**POLLUTANT** — Any dredged spoil, solid waste, incinerator residue, filter backwash, sewage, garbage, refuse, oil, grease, sewage sludge, munitions, chemical wastes, biological materials, medical wastes, radioactive substance [except those regulated under the Atomic Energy Act of 1954, as amended (42 U.S.C. 2011 et seq.)], thermal waste, wrecked or discarded equipment, rock, sand, cellar dirt, industrial, municipal, agricultural, and construction waste or runoff, or other residue discharged directly or indirectly to the land, groundwaters or surface waters of the state, or to a domestic treatment works. "Pollutant" includes both hazardous and nonhazardous pollutants.

**RECHARGE** — The amount of water from precipitation that infiltrates into the ground and is not evapotranspired.

**REGULATED IMPERVIOUS SURFACE** — Any of the following, alone or in combination:**[Added 2-10-2021 by Ord. No. 4-21]**

- A. A net increase of impervious surface;
- B. The total area of impervious surface collected by a new stormwater conveyance system (for the purpose of this definition, a "new stormwater conveyance system" is a stormwater conveyance system that is constructed where one did not exist immediately prior to its construction or an existing system for which a new discharge location is created);
- C. The total area of impervious surface proposed to be newly collected by an existing stormwater conveyance system; and/or
- D. The total area of impervious surface collected by an existing stormwater conveyance system where the capacity of that conveyance system is increased.

**REGULATED MOTOR VEHICLE SURFACE** — Any of the following, alone or in combination:**[Added 2-10-2021 by Ord. No. 4-21]**

- A. The total area of motor vehicle surface that is currently receiving water;
- B. A net increase in motor vehicle surface; and/or
- C. Quality treatment either by vegetation or soil, by an existing stormwater management measure, or by treatment at a wastewater treatment plant, where the water quality treatment will be modified or removed.

**SEDIMENT** — Solid material, mineral or organic, that is in suspension, is being transported, or has been moved from its site of origin by air, water or gravity as a product of erosion.

**SITE** — The lot or lots upon which a major development is to occur or has occurred.

SOIL — All unconsolidated mineral and organic material of any origin.

STATE DEVELOPMENT AND REDEVELOPMENT PLAN METROPOLITAN PLANNING AREA (PA1) — An area delineated on the State Plan Policy Map and adopted by the State Planning Commission that is intended to be the focus for much of the state's future redevelopment and revitalization efforts.

STATE PLAN POLICY MAP — The geographic application of the State Development and Redevelopment Plan's goals and statewide policies, and the official map of these goals and policies.

STORMWATER — Water resulting from precipitation (including rain and snow) that runs off the land's surface, is transmitted to the subsurface, or is captured by separate storm sewers or other sewage or drainage facilities, or conveyed by snow removal equipment.

STORMWATER MANAGEMENT BASIN — An excavation or embankment and related areas designed to retain stormwater runoff. A stormwater management basin may either be normally dry (that is, a detention basin or infiltration basin), retain water in a permanent pool (a retention basin), or be planted mainly with wetland vegetation (most constructed stormwater wetlands).

STORMWATER MANAGEMENT MEASURE — Any structural or nonstructural strategy, practice, technology, process, program, or other method intended to control or reduce stormwater runoff and associated pollutants, or to induce or control the infiltration or groundwater recharge of stormwater or to eliminate illicit or illegal nonstormwater discharges into stormwater conveyances.

STORMWATER MANAGEMENT PLANNING AGENCY — A public body authorized by legislation to prepare stormwater management plans. **[Added 2-10-2021 by Ord. No. 4-21]**

STORMWATER MANAGEMENT PLANNING AREA — The geographic area for which a stormwater management planning agency is authorized to prepare stormwater management plans, or a specific portion of that area identified in a stormwater management plan prepared by that agency. **[Added 2-10-2021 by Ord. No. 4-21]**

STORMWATER RUNOFF — Water flow on the surface of the ground or in storm sewers, resulting from precipitation.

TIDAL FLOOD HAZARD AREA — A flood hazard area in which the flood elevation resulting from the two-, ten-, or 100-year storm, as applicable, is governed by tidal flooding from the Atlantic Ocean. Flooding in a tidal flood hazard area may be contributed to, or influenced by, stormwater runoff from inland areas, but the depth of flooding generated by the tidal rise and fall of the Atlantic Ocean is greater than flooding from any fluvial sources. In some situations, depending upon the extent of the storm surge from a particular storm event, a flood hazard area may be tidal in the 100-year storm, but fluvial in more frequent storm events. **[Amended 2-10-2021 by Ord. No. 4-21]**

TIME OF CONCENTRATION — The time it takes for runoff to travel from the hydraulically most distant point of the watershed to the point of interest within a

watershed.

**TOTAL SUSPENDED SOILS** — The sum of dissolved and undissolved solids and particulate matter of a buoyancy and/or specific gravity that prohibits their settling in runoff.

**URBAN COORDINATING COUNCIL EMPOWERMENT NEIGHBORHOOD** — A neighborhood given priority access to state resources through the New Jersey Redevelopment Authority.

**URBAN ENTERPRISE ZONE** — A zone designated by the New Jersey Enterprise Zone Authority pursuant to the New Jersey Urban Enterprise Zones Act, N.J.S.A. 52:27H-60 et seq.

**URBAN REDEVELOPMENT AREA** — Previously developed portions of areas:

- A. Delineated on the State Plan Policy Map (SPPM) as the Metropolitan Planning Area (PA1), Designated Centers, Cores or Nodes;
- B. Designated as CAFRA Centers, Cores or Nodes;
- C. Designated as Urban Enterprise Zones; and
- D. Designated as Urban Coordinating Council Empowerment Neighborhoods.

**WATER CONTROL STRUCTURE** — A structure within, or adjacent to, a water which intentionally or coincidentally alters the hydraulic capacity, the flood elevation resulting from the two-, ten-, or 100-year storm, flood hazard area limit, and/or floodway limit of the water. Examples of a water control structure may include a bridge, culvert, dam, embankment, ford (if above grade), retaining wall, and weir. **[Added 2-10-2021 by Ord. No. 4-21]**

**WATERS OF THE STATE** — The ocean and its estuaries, all springs, streams, wetlands, and bodies of surface or groundwater, whether natural or artificial, within the boundaries of the State of New Jersey or subject to its jurisdiction.

**WETLANDS or WETLAND** — An area that is inundated or saturated by surface water or groundwater at a frequency and duration sufficient to support, and that under normal circumstances does support, a prevalence of vegetation typically adapted for life in saturated soil conditions, commonly known as "hydrophytic vegetation."

#### **§ 300-25. General standards. [Amended 2-10-2021 by Ord. No. 4-21]**

- A. Stormwater management measures for major development shall be developed to meet the erosion control, groundwater recharge, stormwater runoff quantity, and stormwater runoff quality standards as follows:
  - (1) The minimum standards for erosion control are those established under the Soil Erosion and Sediment Control Act, N.J.S.A. 4:24-39 et seq., and implementing rules at N.J.A.C. 2:90.
  - (2) The minimum standards for groundwater recharge, stormwater quality, and stormwater runoff quantity shall be met by incorporating green infrastructure.

B. The standards in this article apply only to new major development and are intended to minimize the impact of stormwater runoff on water quality and water quantity in receiving water bodies and maintain groundwater recharge. The standards do not apply to new major development to the extent that alternative design and performance standards are applicable under a regional stormwater management plan or water quality management plan adopted in accordance with Department rules.

C. For site improvements regulated under the Residential Site Improvement Standards (RSIS) at N.J.A.C. 5:21, the RSIS shall apply in addition to this article, except to the extent the RSIS are superseded by this article or alternative standards applicable under a regional stormwater management plan or water quality management plan adopted in accordance with the rules of the New Jersey Department of Environmental Protection.

**§ 300-26. Stormwater management requirements for major development.**

A. The development shall incorporate a maintenance plan for the stormwater management measures incorporated into the design of a major development in accordance with § 300-32.

B. Stormwater management measures shall avoid adverse impacts of concentrated flow on habitats for threatened and endangered species as documented in the Department's Landscape Project or Natural Heritage Database established under N.J.S.A. 13:1B-15.147 through 13:1B-15.150, particularly *Helonias bullata* (swamp pink) and/or *Clemmys muhlenbergii* (bog turtle).

C. The following linear development projects are exempt from the groundwater recharge, stormwater runoff quantity, and stormwater runoff quality requirements of Subsections P, Q, and R: **[Amended 2-10-2021 by Ord. No. 4-21]**

- (1) The construction of an underground utility line, provided that the disturbed areas are revegetated upon completion;
- (2) The construction of an aboveground utility line, provided that the existing conditions are maintained to the maximum extent practicable; and
- (3) The construction of a public pedestrian access, such as a sidewalk or trail with a maximum width of 14 feet, provided that the access is made of permeable material.

D. A waiver from strict compliance from the green infrastructure, groundwater recharge, stormwater runoff quantity, and stormwater runoff quality requirements of Subsections O, P, Q, and R may be obtained for the enlargement of an existing public roadway or railroad; or the construction or enlargement of a public pedestrian access, provided that the following conditions are met: **[Amended 2-10-2021 by Ord. No. 4-21]**

- (1) The applicant demonstrates that there is a public need for the project that cannot be accomplished by any other means;

- (2) The applicant demonstrates, through an alternatives analysis, that through the use of nonstructural and structural stormwater management strategies and measures, the option selected complies with the requirements of Subsections O, P, Q, and R to the maximum extent practicable;
- (3) The applicant demonstrates that, in order to meet the requirements of Subsections F and G, existing structures currently in use, such as homes and buildings, would need to be condemned; and
- (4) The applicant demonstrates that it does not own or have other rights to areas, including the potential to obtain through condemnation lands not falling under § 300-26D(3) above within the upstream drainage area of the receiving stream, that would provide additional opportunities to mitigate the requirements of Subsections O, P, Q, and R that were not achievable on site.

E. Nonstructural stormwater management strategies. Table 1 through 3 below summarize the ability of stormwater best management practices identified and described in the New Jersey Stormwater Best Management Practices Manual to satisfy the green infrastructure, groundwater recharge, stormwater runoff quality and stormwater runoff quantity standards specified in Subsections O, P, Q, and R. When designed in accordance with the most current version of the New Jersey Stormwater Best Management Practices Manual, the stormwater management measures found at N.J.A.C. 7:8-5.2(f), Tables 5-1, 5-2 and 5-3, and listed below in Tables 1, 2 and 3 are presumed to be capable of providing stormwater controls for the design and performance standards as outlined in the tables below. Upon amendments of the New Jersey Stormwater Best Management Practices to reflect additions or deletions of BMPs meeting these standards, or changes in the presumed performance of BMPs designed in accordance with the New Jersey Stormwater BMP Manual, the Department shall publish in the New Jersey registers a notice of administrative change revising the applicable table. The most current version of the BMP Manual can be found on the Department's website at [https://njstormwater.org/bmp\\_manual2.htm](https://njstormwater.org/bmp_manual2.htm). **[Amended 2-10-2021 by Ord. No. 4-21]**

F. Where the BMP tables in the New Jersey Stormwater Management Rule are different due to updates or amendments with the tables in this article, the BMP tables in the Stormwater Management Rule at N.J.A.C. 7:8-5.2(f) shall take precedence. **[Amended 2-10-2021 by Ord. No. 4-21]**

**Table 1**  
**Green Infrastructure BMPs for Groundwater Recharge, Stormwater Runoff**  
**Quality, and/or Stormwater Runoff Quantity**

Best Management Practice	Stormwater Runoff Quality TSS Removal Rate	Stormwater Runoff Quantity	Groundwater Recharge	Minimum Separation from Seasonal High-Water Table (feet)
Cistern	0%	Yes	No	—
Dry well <sup>(a)</sup>	0%	No	Yes	2
Grass swale	50% or less	No	No	2 <sup>(e)</sup> 1 <sup>(f)</sup>
Green roof	0%	Yes	No	—
Manufactured treatment device <sup>(a)(g)</sup>	50% or 80%	No	No	Dependent upon the device
Pervious paving system <sup>(a)</sup>	80%	Yes	Yes <sup>(b)</sup> No <sup>(c)</sup>	2 <sup>(b)</sup> 1 <sup>(c)</sup>
Small-scale bioretention basin <sup>(a)</sup>	80% or 90%	Yes	Yes <sup>(b)</sup> No <sup>(c)</sup>	2 <sup>(b)</sup> 1 <sup>(c)</sup>
Small-scale infiltration basin <sup>(a)</sup>	80%	Yes	Yes	2
Small-scale sand filter	80%	Yes	Yes	2
Vegetative filter strip	60% to 80%	No	No	—

**Table 2**  
**Green Infrastructure BMPs for Stormwater Runoff Quantity**  
**(or for Groundwater Recharge and/or Stormwater Runoff Quality with a Waiver**  
**or Variance from N.J.A.C. 7:8-5.3)**

Best Management Practice	Stormwater Runoff Quality TSS Removal Rate	Stormwater Runoff Quantity	Groundwater Recharge	Minimum Separation from Seasonal High-Water Table (feet)
Bioretention system	80% or 90%	Yes	Yes <sup>(b)</sup> No <sup>(c)</sup>	2 <sup>(b)</sup> 1 <sup>(c)</sup>
Infiltration basin	80%	Yes	Yes	2
Sand filter <sup>(b)</sup>	80%	Yes	Yes	2
Standard constructed wetland	90%	Yes	No	N/A
Wet pond <sup>(d)</sup>	50% to 90%	Yes	No	N/A

**Table 3**  
**BMPs for Groundwater Recharge, Stormwater Runoff Quality, and/or**  
**Stormwater Runoff Quantity**  
**only with a Waiver or Variance from N.J.A.C. 7:8-5.3**

Best Management Practice	Stormwater Runoff Quality TSS Removal Rate	Stormwater Runoff Quantity	Groundwater Recharge	Minimum Separation from Seasonal High-Water Table (feet)
Blue roof	0%	Yes	No	N/A
Extended detention basin	40% to 60%	Yes	No	1
Manufactured treatment device <sup>(h)</sup>	50% or 80%	No	No	Dependent upon the device
Sand filter <sup>(c)</sup>	80%	Yes	No	1
Subsurface gravel wetland	90%	No	No	1

**Table 3**  
**BMPs for Groundwater Recharge, Stormwater Runoff Quality, and/or**  
**Stormwater Runoff Quantity**  
**only with a Waiver or Variance from N.J.A.C. 7:8-5.3**

Best Management Practice	Stormwater Runoff Quality TSS Removal Rate	Stormwater Runoff Quantity	Groundwater Recharge	Minimum Separation from Seasonal High-Water Table (feet)
Wet pond	50% to 90%	Yes	No	N/A

Notes to Tables 1, 2, and 3:

- (a) Subject to the applicable contributory drainage area limitation specified at Subsection O(2).
- (b) Designed to infiltrate into the subsoil.
- (c) Designed with underdrains.
- (d) Designed to maintain at least a ten-foot-wide area of native vegetation along at least 50% of the shoreline and to include a stormwater runoff retention component designed to capture stormwater runoff for beneficial reuse, such as irrigation.
- (e) Designed with a slope of less than 2%.
- (f) Designed with a slope of equal to or greater than 2%.
- (g) Manufactured treatment devices that meet the definition of "green infrastructure" at § 300-24.
- (h) Manufactured treatment devices that do not meet the definition of "green infrastructure" at § 300-24.

G. An alternative stormwater management measure, alternative removal rate, and/or alternative method to calculate the removal rate may be used if the design engineer demonstrates the capability of the proposed alternative stormwater management measure and/or the validity of the alternative rate or method to the municipality. A copy of any approved alternative stormwater management measure, alternative removal rate, and/or alternative method to calculate the removal rate shall be provided to the Department in accordance with § 300-28B. Alternative stormwater management measures may be used to satisfy the requirements at Subsection O only if the measures meet the definition of "green infrastructure" at § 300-24. Alternative stormwater management measures that function in a similar manner to a BMP listed at Subsection O(2) are subject to the contributory drainage area limitation specified at Subsection O(2) for that similarly functioning BMP. Alternative stormwater management measures approved in accordance with this subsection that do not function in a similar manner to any BMP listed at Subsection

O(2) shall have a contributory drainage area less than or equal to 2.5 acres, except for alternative stormwater management measures that function similarly to cisterns, grass swales, green roofs, standard constructed wetlands, vegetative filter strips, and wet ponds, which are not subject to a contributory drainage area limitation. Alternative measures that function similarly to standard constructed wetlands or wet ponds shall not be used for compliance with the stormwater runoff quality standard unless a variance in accordance with N.J.A.C. 7:8-4.6 or a waiver from strict compliance in accordance with Subsection D is granted from Subsection O. **[Amended 2-10-2021 by Ord. No. 4-21]**

- H. Whenever the stormwater management design includes one or more BMPs that will infiltrate stormwater into subsoil, the design engineer shall assess the hydraulic impact on the groundwater table and design the site, so as to avoid adverse hydraulic impacts. Potential adverse hydraulic impacts include, but are not limited to, exacerbating a naturally or seasonally high-water table, so as to cause surficial ponding, flooding of basements, or interference with the proper operation of subsurface sewage disposal systems or other subsurface structures within the zone of influence of the groundwater mound, or interference with the proper functioning of the stormwater management measure itself. **[Added 2-10-2021 by Ord. No. 4-21]**
- I. Design standards for stormwater management measures are as follows: **[Added 2-10-2021 by Ord. No. 4-21]**
  - (1) Stormwater management measures shall be designed to take into account the existing site conditions, including, but not limited to, environmentally critical areas; wetlands; flood-prone areas; slopes; depth to seasonal high-water table; soil type, permeability, and texture; drainage area and drainage patterns; and the presence of solution-prone carbonate rocks (limestone);
  - (2) Stormwater management measures shall be designed to minimize maintenance, facilitate maintenance and repairs, and ensure proper functioning. Trash racks shall be installed at the intake to the outlet structure, as appropriate, and shall have parallel bars with one-inch spacing between the bars to the elevation of the water quality design storm. For elevations higher than the water quality design storm, the parallel bars at the outlet structure shall be spaced no greater than 1/3 the width of the diameter of the orifice or 1/3 the width of the weir, with a minimum spacing between bars of one inch and a maximum spacing between bars of six inches. In addition, the design of trash racks must comply with the requirements of § 300-30C;
  - (3) Stormwater management measures shall be designed, constructed, and installed to be strong, durable, and corrosion resistant. Measures that are consistent with the relevant portions of the Residential Site Improvement Standards at N.J.A.C. 5:21-7.3, 5:21-7.4, and 5:21-7.5 shall be deemed to meet this requirement;
  - (4) Stormwater management BMPs shall be designed to meet the minimum safety standards for stormwater management BMPs at § 300-30; and

(5) The size of the orifice at the intake to the outlet from the stormwater management BMP shall be a minimum of 2 1/2 inches in diameter.

J. Manufactured treatment devices may be used to meet the requirements of this section, provided the pollutant removal rates are verified by the New Jersey Corporation for Advanced Technology and certified by the Department. Manufactured treatment devices that do not meet the definition of "green infrastructure" at § 300-24 may be used only under the circumstances described at Subsection O(4). **[Added 2-10-2021 by Ord. No. 4-21]**

K. Any application for a new agricultural development that meets the definition of "major development" at § 300-24 shall be submitted to the soil conservation district for review and approval in accordance with the requirements at Subsections O, P, Q and R and any applicable soil conservation district guidelines for stormwater runoff quantity and erosion control. For purposes of this subsection, "agricultural development" means land uses normally associated with the production of food, fiber, and livestock for sale. Such uses do not include the development of land for the processing or sale of food and the manufacture of agriculturally related products. **[Added 2-10-2021 by Ord. No. 4-21]**

L. If there is more than one drainage area, the groundwater recharge, stormwater runoff quality, and stormwater runoff quantity standards at Subsections P, Q and R shall be met in each drainage area, unless the runoff from the drainage areas converge on-site and no adverse environmental impact would occur as a result of compliance with any one or more of the individual standards being determined utilizing a weighted average of the results achieved for that individual standard across the affected drainage areas. **[Added 2-10-2021 by Ord. No. 4-21]**

M. Any stormwater management measure authorized under the municipal stormwater management plan or ordinance shall be reflected in a deed notice recorded in the office of the Monmouth County Clerk. A form of deed notice shall be submitted to the municipality for approval prior to filing. The deed notice shall contain a description of the stormwater management measure(s) used to meet the green infrastructure, groundwater recharge, stormwater runoff quality, and stormwater runoff quantity standards at Subsections O, P, Q and R and shall identify the location of the stormwater management measure(s) in NAD 1983 State Plane New Jersey FIPS 2900 US feet or latitude and longitude in decimal degrees. The deed notice shall also reference the maintenance plan required to be recorded upon the deed pursuant to § 300-32B(5). Prior to the commencement of construction, proof that the above required deed notice has been filed shall be submitted to the municipality. Proof that the required information has been recorded on the deed shall be in the form of either a copy of the complete recorded document or a receipt from the Clerk or other proof of recordation provided by the recording office. However, if the initial proof provided to the municipality is not a copy of the complete recorded document, a copy of the complete recorded document shall be provided to the municipality within 180 calendar days of the authorization granted by the municipality. **[Added 2-10-2021 by Ord. No. 4-21]**

N. A stormwater management measure approved under the municipal stormwater management plan or ordinance may be altered or replaced with the approval of the municipality, if the municipality determines that the proposed alteration or replacement meets the design and performance standards pursuant to § 300-26 of this article and provides the same level of stormwater management as the previously approved stormwater management measure that is being altered or replaced. If an alteration or replacement is approved, a revised deed notice shall be submitted to the municipality for approval and subsequently recorded with the office of the Monmouth County Clerk and shall contain a description and location of the stormwater management measure, as well as reference to the maintenance plan, in accordance with Subsection M above. Prior to the commencement of construction, proof that the above required deed notice has been filed shall be submitted to the municipality in accordance with Subsection M above. **[Added 2-10-2021 by Ord. No. 4-21]**

O. Green infrastructure standards. **[Added 2-10-2021 by Ord. No. 4-21]**

- (1) This subsection specifies the types of green infrastructure BMPs that may be used to satisfy the groundwater recharge, stormwater runoff quality, and stormwater runoff quantity standards.
- (2) To satisfy the groundwater recharge and stormwater runoff quality standards at Subsections P and Q, the design engineer shall utilize green infrastructure BMPs identified in Table 1 at Subsection F and/or an alternative stormwater management measure approved in accordance with Subsection G. The following green infrastructure BMPs are subject to the following maximum contributory drainage area limitations:

Best Management Practice	Maximum Contributory Drainage Area (acres)
Dry well	1
Manufactured treatment device	2.5
Pervious pavement systems	Area of additional inflow cannot exceed 3 times the area occupied by the BMP
Small-scale bioretention systems	2.5
Small-scale infiltration basin	2.5
Small-scale sand filter	2.5

- (3) To satisfy the stormwater runoff quantity standards at Subsection R, the design engineer shall utilize BMPs from Table 1 or from Table 2 and/or an alternative stormwater management measure approved in accordance with Subsection G.
- (4) If a variance in accordance with N.J.A.C. 7:8-4.6 or a waiver from strict

compliance in accordance with Subsection D is granted from the requirements of this subsection, then BMPs from Table 1, 2, or 3 and/or an alternative stormwater management measure approved in accordance with Subsection G may be used to meet the groundwater recharge, stormwater runoff quality, and stormwater runoff quantity standards at Subsections P, Q and R.

- (5) For separate or combined storm sewer improvement projects, such as sewer separation, undertaken by a government agency or public utility (for example, a sewerage company), the requirements of this subsection shall only apply to areas owned in fee simple by the government agency or utility and areas within a right-of-way or easement held or controlled by the government agency or utility; the entity shall not be required to obtain additional property or property rights to fully satisfy the requirements of this subsection. Regardless of the amount of area of a separate or combined storm sewer improvement project subject to the green infrastructure requirements of this subsection, each project shall fully comply with the applicable groundwater recharge, stormwater runoff quality control, and stormwater runoff quantity standards at Subsections P, Q and R, unless the project is granted a waiver from strict compliance in accordance with Subsection D.

P. Groundwater recharge standards. **[Added 2-10-2021 by Ord. No. 4-21]**

- (1) This subsection contains the minimum design and performance standards for groundwater recharge as follows.
  - (2) The design engineer shall, using the assumptions and factors for stormwater runoff and groundwater recharge calculations at § 300-27, either:
    - (a) Demonstrate through hydrologic and hydraulic analysis that the site and its stormwater management measures maintain 100% of the average annual preconstruction groundwater recharge volume for the site; or
    - (b) Demonstrate through hydrologic and hydraulic analysis that the increase of stormwater runoff volume from preconstruction to post-construction for the two-year storm is infiltrated.
  - (3) This groundwater recharge requirement does not apply to projects within the urban redevelopment area, or to projects subject to Subsection P(4) below.
  - (4) The following types of stormwater shall not be recharged:
    - (a) Stormwater from areas of high pollutant loading. High pollutant loading areas are areas in industrial and commercial developments where solvents and/or petroleum products are loaded/unloaded, stored, or applied, areas where pesticides are loaded/unloaded or stored; areas where hazardous materials are expected to be present in greater than "reportable quantities" as defined by the United States Environmental Protection Agency (EPA) at 40 CFR 302.4; areas where recharge would be inconsistent with a Department-approved remedial action work plan or landfill closure plan and areas with high risks for spills of toxic materials, such as gas stations

and vehicle maintenance facilities; and

(b) Industrial stormwater exposed to source material. "Source material" means any material(s) or machinery, located at an industrial facility, that is directly or indirectly related to process, manufacturing or other industrial activities, which could be a source of pollutants in any industrial stormwater discharge to groundwater. Source materials include, but are not limited to, raw materials; intermediate products; final products; waste materials; by-products; industrial machinery and fuels and lubricants, solvents, and detergents that are related to process, manufacturing, or other industrial activities that are exposed to stormwater.

**Q. Stormwater runoff quality standards. [Added 2-10-2021 by Ord. No. 4-21]**

- (1) This subsection contains the minimum design and performance standards to control stormwater runoff quality impacts of major development. Stormwater runoff quality standards are applicable when the major development results in an increase of 1/4 acre or more of regulated motor vehicle surface.
- (2) Stormwater management measures shall be designed to reduce the post-construction load of total suspended solids (TSS) in stormwater runoff generated from the water quality design storm as follows:
  - (a) 80% TSS removal of the anticipated load, expressed as an annual average shall be achieved for the stormwater runoff from the net increase of motor vehicle surface.
  - (b) If the surface is considered regulated motor vehicle surface because the water quality treatment for an area of motor vehicle surface that is currently receiving water quality treatment either by vegetation or soil, by an existing stormwater management measure, or by treatment at a wastewater treatment plant is to be modified or removed, the project shall maintain or increase the existing TSS removal of the anticipated load expressed as an annual average.
- (3) The requirement to reduce TSS does not apply to any stormwater runoff in a discharge regulated under a numeric effluent limitation for TSS imposed under the New Jersey Pollutant Discharge Elimination System (NJPDES) rules, N.J.A.C. 7:14A, or in a discharge specifically exempt under a NJPDES permit from this requirement. Every major development, including any that discharge into a combined sewer system, shall comply with Subsection Q(2) above, unless the major development is itself subject to an NJPDES permit with a numeric effluent limitation for TSS or the NJPDES permit to which the major development is subject exempts the development from a numeric effluent limitation for TSS.
- (4) The water quality design storm is 1.25 inches of rainfall in two hours. Water quality calculations shall take into account the distribution of rain from the

water quality design storm, as reflected in Table 4, below. The calculation of the volume of runoff may take into account the implementation of stormwater management measures.

Table 4 Water Quality Design Storm Distribution					
Time (minutes)	Cumulative Rainfall (inches)	Time (minutes)	Cumulative Rainfall (inches)	Time (minutes)	Cumulative Rainfall (inches)
1	0.00166	41	0.1728	81	1.0906
2	0.00332	42	0.1796	82	1.0972
3	0.00498	43	0.1864	83	1.1038
4	0.00664	44	0.1932	84	1.1104
5	0.00830	45	0.2000	85	1.1170
6	0.00996	46	0.2117	86	1.1236
7	0.01162	47	0.2233	87	1.1302
8	0.01328	48	0.2350	88	1.1368
9	0.01494	49	0.2466	89	1.1434
10	0.01660	50	0.2583	90	1.1500
11	0.01828	51	0.2783	91	1.1550
12	0.01996	52	0.2983	92	1.1600
13	0.02164	53	0.3183	93	1.1650
14	0.02332	54	0.3383	94	1.1700
15	0.02500	55	0.3583	95	1.1750
16	0.03000	56	0.4116	96	1.1800
17	0.03500	57	0.4650	97	1.1850
18	0.04000	58	0.5183	98	1.1900
19	0.04500	59	0.5717	99	1.1950
20	0.05000	60	0.6250	100	1.2000
21	0.05500	61	0.6783	101	1.2050
22	0.06000	62	0.7317	102	1.2100
23	0.06500	63	0.7850	103	1.2150
24	0.07000	64	0.8384	104	1.2200
25	0.07500	65	0.8917	105	1.2250

Table 4

Water Quality Design Storm Distribution

Time (minutes)	Cumulative Rainfall (inches)	Time (minutes)	Cumulative Rainfall (inches)	Time (minutes)	Cumulative Rainfall (inches)
26	0.08000	66	0.9117	106	1.2267
27	0.08500	67	0.9317	107	1.2284
28	0.09000	68	0.9517	108	1.2300
29	0.09500	69	0.9717	109	1.2317
30	0.10000	70	0.9917	110	1.2334
31	0.10660	71	1.0034	111	1.2351
32	0.11320	72	1.0150	112	1.2367
33	0.11980	73	1.0267	113	1.2384
34	0.12640	74	1.0383	114	1.2400
35	0.13300	75	1.0500	115	1.2417
36	0.13960	76	1.0568	116	1.2434
37	0.14620	77	1.0636	117	1.2450
38	0.15280	78	1.0704	118	1.2467
39	0.15940	79	1.0772	119	1.2483
40	0.16600	80	1.0840	120	1.2500

(5) If more than one BMP in series is necessary to achieve the required 80% TSS reduction for a site, the applicant shall utilize the following formula to calculate TSS reduction:

$$R = A + B - (A \times B)/100$$

Where:

R = total TSS percent load removal from application of both BMPs.

A = the TSS percent removal rate applicable to the first BMP.

B = the TSS percent removal rate applicable to the second BMP.

(6) Stormwater management measures shall also be designed to reduce, to the maximum extent feasible, the post-construction nutrient load of the anticipated load from the developed site in stormwater runoff generated from the water

quality design storm. In achieving reduction of nutrients to the maximum extent feasible, the design of the site shall include green infrastructure BMPs that optimize nutrient removal while still achieving the performance standards in Subsection P, Q and R.

- (7) In accordance with the definition of "FW1" at N.J.A.C. 7:9B-1.4, stormwater management measures shall be designed to prevent any increase in stormwater runoff to waters classified as "FW1."
- (8) The Flood Hazard Area Control Act Rules at N.J.A.C. 7:13-4.1(c)(1) establish 300-foot riparian zones along Category One waters, as designated in the Surface Water Quality Standards at N.J.A.C. 7:9B, and certain upstream tributaries to Category One waters. A person shall not undertake a major development that is located within or discharges into a 300-foot riparian zone without prior authorization from the Department under N.J.A.C. 7:13.
- (9) Pursuant to the Flood Hazard Area Control Act Rules at N.J.A.C. 7:13-11.2(j)3i runoff from the water quality design storm that is discharged within a 300-foot riparian zone shall be treated in accordance with this subsection to reduce the post-construction load of total suspended solids by 95% of the anticipated load from the developed site, expressed as an annual average.
- (10) These stormwater runoff quality standards do not apply to the construction of one individual single-family dwelling, provided that it is not part of a larger development or subdivision that has received preliminary or final site plan approval prior to December 3, 2018, and that the motor vehicle surfaces are made of permeable material(s) such as gravel, dirt, and/or shells.

R. Stormwater runoff quantity standards. **[Added 2-10-2021 by Ord. No. 4-21]**

- (1) This subsection contains the minimum design and performance standards to control stormwater runoff quantity impacts of major development.
- (2) In order to control stormwater runoff quantity impacts, the design engineer shall, using the assumptions and factors for stormwater runoff calculations at § 300-27, complete one of the following:
  - (a) Demonstrate through hydrologic and hydraulic analysis that for stormwater leaving the site, post-construction runoff hydrographs for the two-, ten-, and 100-year storm events do not exceed, at any point in time, the preconstruction runoff hydrographs for the same storm events;
  - (b) Demonstrate through hydrologic and hydraulic analysis that there is no increase, as compared to the preconstruction condition, in the peak runoff rates of stormwater leaving the site for the two-, ten- and 100-year storm events and that the increased volume or change in timing of stormwater runoff will not increase flood damage at or downstream of the site. This analysis shall include the analysis of impacts of existing land uses and projected land uses assuming full development under existing zoning and

land use ordinances in the drainage area;

- (c) Design stormwater management measures so that the post-construction peak runoff rates for the two-, ten- and 100-year storm events are 50%, 75% and 80%, respectively, of the preconstruction peak runoff rates. The percentages apply only to the post-construction stormwater runoff that is attributable to the portion of the site on which the proposed development or project is to be constructed; or
- (d) In tidal flood hazard areas, stormwater runoff quantity analysis in accordance with Subsection R(2)(a), (b) and (c) above is required unless the design engineer demonstrates through hydrologic and hydraulic analysis that the increased volume, change in timing, or increased rate of the stormwater runoff, or any combination of the three, will not result in additional flood damage below the point of discharge of the major development. No analysis is required if the stormwater is discharged directly into any ocean, bay, inlet, or the reach of any watercourse between its confluence with an ocean, bay, or inlet and downstream of the first water control structure.

(3) The stormwater runoff quantity standards shall be applied at the site's boundary to each abutting lot, roadway, watercourse, or receiving storm sewer system.

### **§ 300-27. Calculation of stormwater runoff and groundwater recharge.**

A. Stormwater runoff shall be calculated in accordance with the following:

- (1) The design engineer shall calculate runoff using one of the following methods:
  - (a) The USDA Natural Resources Conservation Service (NRCS) methodology, including the NRCS Runoff Equation and Dimensionless Unit Hydrograph, as described in Chapters 7, 9, 10, 15 and 16, Part 630, Hydrology National Engineering Handbook, incorporated herein by reference, as amended and supplemented. This methodology is additionally described in Technical Release 55 - Urban Hydrology for Small Watersheds (TR-55), dated June 1986, incorporated herein by reference, as amended and supplemented. Information regarding the methodology is available from the Natural Resources Conservation Service website at [https://www.nrcs.usda.gov/Internet/FSE\\_DOCUMENTS/stelprdb1044171.pdf](https://www.nrcs.usda.gov/Internet/FSE_DOCUMENTS/stelprdb1044171.pdf) or at United States Department of Agriculture Natural Resources Conservation Service, 220 Davison Avenue, Somerset, New Jersey 08873; or **[Amended 2-10-2021 by Ord. No. 4-21]**
  - (b) The Rational Method for peak flow and the Modified Rational Method for hydrograph computations. The Rational and Modified Rational Methods are described in Appendix A-9 Modified Rational Method in the Standards for Soil Erosion and Sediment Control in New Jersey, January

2014. This document is available from the State Soil Conservation Committee or any of the soil conservation districts listed at N.J.A.C. 2:90-1.3(a)3. The location, address, and telephone number for each soil conservation district is available from the State Soil Conservation Committee, PO Box 330, Trenton, New Jersey 08625. The document is also available at: <http://www.nj.gov/agriculture/divisions/anr/pdf/2014NJSoilErosionControlStandardsComplete.pdf>. [Amended 2-10-2021 by Ord. No. 4-21]

- (2) For the purpose of calculating runoff coefficients and groundwater recharge, there is a presumption that the preconstruction condition of a site or portion thereof is a wooded land use with good hydrologic condition. The term "runoff coefficient" applies to both the NRCS methodology at Subsection A(1)(a) and the Rational and Modified Rational Methods at Subsection A(1)(b). A runoff coefficient or a groundwater recharge land cover for an existing condition may be used on all or a portion of the site if the design engineer verifies that the hydrologic condition has existed on the site or portion of the site for at least five years without interruption prior to the time of application. If more than one land cover has existed on the site during the five years immediately prior to the time of application, the land cover with the lowest runoff potential shall be used for the computations. In addition, there is the presumption that the site is in good hydrologic condition (if the land use type is pasture, lawn, or park), with good cover (if the land use type is woods), or with good hydrologic condition and conservation treatment (if the land use type is cultivation).
- (3) In computing preconstruction stormwater runoff, the design engineer shall account for all significant land features and structures, such as ponds, wetlands, depressions, hedgerows, or culverts that may reduce preconstruction stormwater runoff rates and volumes.
- (4) In computing stormwater runoff from all design storms, the design engineer shall consider the relative stormwater runoff rates and/or volumes of pervious and impervious surfaces separately to accurately compute the rates and volume of stormwater runoff from the site. To calculate runoff from unconnected impervious cover, urban impervious area modifications as described in the NRCS Technical Release 55 – Urban Hydrology for Small Watersheds and other methods may be employed.
- (5) If the invert of the outlet structure of a stormwater management measure is below the flood hazard design flood elevation as defined at N.J.A.C. 7:13, the design engineer shall take into account the effects of tailwater in the design of structural stormwater management measures.

B. Groundwater recharge may be calculated in accordance with the following: The New Jersey Geological Survey Report GSR-32, A Method for Evaluating Ground-Water Recharge Areas in New Jersey, incorporated herein by reference as amended and supplemented. Information regarding the methodology is available from the New Jersey Stormwater Best Management Practices Manual; at

<http://www.state.nj.us/dep/njgs/>; or at New Jersey Geological Survey, 29 Arctic Parkway, P.O. Box 427 Trenton, New Jersey 08625-0427; (609) 984-6587.

**§ 300-28. Sources for technical guidance. [Amended 2-10-2021 by Ord. No. 4-21]**

- A. Technical guidance for stormwater management measures can be found in the documents listed below, which are available to download from the Department's website at [http://www.nj.gov/dep/stormwater/bmp\\_manual2.htm](http://www.nj.gov/dep/stormwater/bmp_manual2.htm).
  - (1) Guidelines for stormwater management measures are contained in the New Jersey Stormwater Best Management Practices Manual, as amended and supplemented. Information is provided on stormwater management measures such as, but not limited to, those listed in Tables 1, 2, and 3.
  - (2) Additional maintenance guidance is available on the Department's website at [https://www.njstormwater.org/maintenance\\_guidance.htm](https://www.njstormwater.org/maintenance_guidance.htm).
- B. Submissions required for review by the Department should be mailed to the Division of Water Quality, New Jersey Department of Environmental Protection, Mail Code 401-02B, PO Box 420, Trenton, New Jersey 08625-0420.
- C. Additional technical guidance for stormwater management measures can be obtained from the following:
  - (1) The Standards for Soil Erosion and Sediment Control in New Jersey, promulgated by the State Soil Conservation Committee and incorporated into N.J.A.C. 2:90. Copies of these standards may be obtained by contacting the State Soil Conservation Committee or any of the soil conservation districts listed in N.J.A.C. 2:90-1.3(a)4. The location, address, and telephone number of each soil conservation district may be obtained from the State Soil Conservation Committee, P.O. Box 330, Trenton, New Jersey 08625; (609) 292-5540;
  - (2) The Rutgers Cooperative Extension Service, (732)-932-9306; and
  - (3) The soil conservation districts listed in N.J.A.C. 2:90-1.3(a)4. The location, address, and telephone number of each soil conservation district may be obtained from the State Soil Conservation Committee, P.O. Box 330, Trenton, New Jersey 08625; (609) 292-5540.

**§ 300-29. Solids and floatable materials control standards. [Amended 2-10-2021 by Ord. No. 4-21]**

- A. Site design features identified under § 300-26F, or alternative designs in accordance with § 300-26G, to prevent discharge of trash and debris from drainage systems shall comply with the following standard to control passage of solid and floatable materials through storm drain inlets. For purposes of this subsection, "solid and floatable materials" means sediment, debris, trash, and other floating, suspended, or settleable solids. For exemptions to this standard see § 300-29A(2) below.

- (1) Design engineers shall use one of the following grates whenever they use a grate in pavement or another ground surface to collect stormwater from that surface into a storm drain or surface water body under that grate:
  - (a) The New Jersey Department of Transportation (NJDOT) bicycle-safe grate, which is described in Chapter 2.4 of the NJDOT Bicycle Compatible Roadways and Bikeways Planning and Design Guidelines; or
  - (b) A different grate, if each individual clear space in that grate has an area of no more than 7.0 square inches, or is no greater than 0.5 inch across the smallest dimension. Examples of grates subject to this standard include grates in grate inlets, the grate portion (non-curb-opening portion) of combination inlets, grates on storm sewer manholes, ditch grates, trench grates, and grates of spacer bars in slotted drains. Examples of ground surfaces include surfaces of roads (including bridges), driveways, parking areas, bikeways, plazas, sidewalks, lawns, fields, open channels, and stormwater system floors used to collect stormwater from the surface into a storm drain or surface water body.
  - (c) For curb-opening inlets, including curb-opening inlets in combination inlets, the clear space in that curb opening, or each individual clear space if the curb opening has two or more clear spaces, shall have an area of no more than 7.0 square inches, or be no greater than 2.0 inches across the smallest dimension.
- (2) The standard in Subsection A(1) above does not apply:
  - (a) Where each individual clear space in the curb opening in an existing curb-opening inlet does not have an area of more than 9.0 square inches;
  - (b) Where the municipality agrees that the standards would cause inadequate hydraulic performance that could not practicably be overcome by using additional or larger storm drain inlets;
  - (c) Where flows from the water quality design storm as specified in N.J.A.C. 7:8 are conveyed through any device (e.g., end of pipe netting facility, manufactured treatment device, or a catch basin hood) that is designed, at a minimum, to prevent delivery of all solid and floatable materials that could not pass through one of the following:
    - [1] A rectangular space 4 5/8 (4.625) inches long and 1 1/2 (1.5) inches wide (this option does not apply for outfall netting facilities); or
    - [2] A bar screen having a bar spacing of 0.5 inch. Note that these exemptions do not authorize any infringement of requirements in the Residential Site Improvement Standards for bicycle-safe grates in new residential development (N.J.A.C. 5:21-4.18(b)2 and 5:21-7.4(b)1).
  - (d) Where flows are conveyed through a trash rack that has parallel bars with

one-inch spacing between the bars, to the elevation of the water quality design storm as specified in N.J.A.C. 7:8; or

(e) Where the New Jersey Department of Environmental Protection determines, pursuant to the New Jersey Register of Historic Places Rules at N.J.A.C. 7:4-7.2(c), that action to meet this standard is an undertaking that constitutes an encroachment or will damage or destroy the New Jersey Register-listed historic property.

**§ 300-30. Safety standards for stormwater management basins.**

A. This section sets forth requirements to protect public safety through the proper design and operation of stormwater management basins. This section applies to any new stormwater management basin.

B. The provisions of this section are not intended to preempt more stringent municipal or county safety requirements for new or existing stormwater management BMPs. Municipal and county stormwater management plans and ordinances may, pursuant to their authority, require existing stormwater management BMPs to be retrofitted to meet one or more of the safety standards in § 300-30C(1), (2), and (3) for trash racks, overflow grates, and escape provisions at outlet structures. **[Amended 2-10-2021 by Ord. No. 4-21]**

C. Requirements for trash racks, overflow grates and escape provisions. **[Amended 2-10-2021 by Ord. No. 4-21]**

(1) A trash rack is a device designed to catch trash and debris and prevent the clogging of outlet structures. Trash racks shall be installed at the intake to the outlet from the stormwater management basin to ensure proper functioning of the basin outlets in accordance with the following:

(a) The trash rack shall have parallel bars, with no greater than six-inch spacing between the bars.

(b) The trash rack shall be designed so as not to adversely affect the hydraulic performance of the outlet pipe or structure.

(c) The average velocity of flow through a clean trash rack is not to exceed 2.5 feet per second under the full range of stage and discharge. Velocity is to be computed on the basis of the net area of opening through the rack.

(d) The trash rack shall be constructed and installed to be rigid, durable, and corrosion resistant and shall be designed to withstand a perpendicular live loading of 300 pounds per square foot.

(2) An overflow grate is designed to prevent obstruction of the overflow structure. If an outlet structure has an overflow grate, such grate shall meet the following requirements:

(a) The overflow grate shall be secured to the outlet structure but removable

for emergencies and maintenance.


- (b) The overflow grate spacing shall be no less than two inches across the smallest dimension.
- (c) The overflow grate shall be constructed and installed to be rigid, durable, and corrosion resistant and shall be designed to withstand a perpendicular live loading of 300 pounds per square foot.

(3) For purposes of this subsection, "escape provisions" means the permanent installation of ladders, steps, rungs, or other features that provide easily accessible means of egress from stormwater management basins. Stormwater management basins shall include escape provisions as follows:

- (a) If a stormwater management basin has an outlet structure, escape provisions shall be incorporated in or on the structure. With the prior approval of the reviewing agency identified in Subsection D, a freestanding outlet structure may be exempted from this requirement.
- (b) Safety ledges shall be constructed on the slopes of all new stormwater management basins having a permanent pool of water deeper than 2 1/2 feet. Such safety ledges shall be comprised of two steps. Each step shall be four feet to six feet in width. One step shall be located approximately 2 1/2 feet below the permanent water surface, and the second step shall be located one foot to 1 1/2 feet above the permanent water surface. See Subsection E for an illustration of safety ledges in a stormwater management basin.
- (c) In new stormwater management basins, the maximum interior slope for an earthen dam, embankment, or berm shall not be steeper than three horizontal to one vertical.

D. Variance or exemption from safety standards. A variance or exemption from the safety standards for stormwater management basins may be granted only upon a written finding by the appropriate reviewing agency (municipality, county or Department) that the variance or exemption will not constitute a threat to public safety. **[Amended 2-10-2021 by Ord. No. 4-21]**

E. Illustration of safety ledges in a new stormwater management basin. **[Added 2-10-2021 by Ord. No. 4-21]**



### **§ 300-31. Requirements for a site development stormwater plan.**

- A. Submission of site development stormwater plan.
  - (1) Whenever an applicant seeks municipal approval of a development subject to this article, the applicant shall submit all of the required components of the checklist for the site development stormwater plan at Subsection C as part of the submission of the applicant's application for subdivision or site plan approval.
  - (2) The applicant shall demonstrate that the project meets the standards set forth in this article.
  - (3) The applicant shall submit 14 copies of the materials listed in the checklist for site development stormwater plans in accordance with § 300-31C of this article.
- B. Site development stormwater plan approval. The applicant's site development project shall be reviewed as a part of the subdivision or site plan review process by the municipal board or official from whom municipal approval is sought. That municipal board or official shall consult the engineer retained by the Planning and/or Zoning Board (as appropriate) to determine if all of the checklist requirements have been satisfied and to determine if the project meets the standards set forth in this article.
- C. Checklist requirements. The following information shall be required:
  - (1) Topographic base map. The reviewing engineer may require upstream tributary drainage system information as necessary. It is recommended that the topographic base map of the site be submitted which extends a minimum of

200 feet beyond the limits of the proposed development, at a scale of one inch equals 200 feet or greater, showing two-foot contour intervals. The map as appropriate may indicate the following: existing surface water drainage, shorelines, steep slopes, soils, erodible soils, perennial or intermittent streams, waterways that drain into or upstream of the Category One waters, wetlands and floodplains along with their appropriate buffer strips, marshlands and other wetlands, pervious or vegetative surfaces, existing man-made structures, roads, bearing and distances of property lines, and significant natural and man-made features not otherwise shown.

- (2) Environmental site analysis: a written and graphic description of the natural and man-made features of the site and its environs. This description should include a discussion of soil conditions, slopes, wetlands, waterways and vegetation on the site. Particular attention should be given to unique, unusual, or environmentally sensitive features and to those that provide particular opportunities or constraints for development.
- (3) Project description and site plan(s): a map (or maps) at the scale of the topographical base map indicating the location of areas of impervious surface, including but not limited to existing and proposed buildings, roads, parking areas, utilities, structural facilities for stormwater management and sediment control, and other permanent structures. The map(s) shall also clearly show areas where alterations occur in the natural terrain and cover, including lawns and other landscaping, and seasonal high groundwater elevations. A written description of the site plan and justification of proposed changes in natural conditions shall also be provided.
- (4) Land use planning and source control plan. This plan shall provide a demonstration of how the goals and standards of §§ 300-25 through 300-28 are being met. The focus of this plan shall be to describe how the site is being developed to meet the objective of controlling groundwater recharge, stormwater quality and stormwater quantity problems at the source by land management and source controls whenever possible.
- (5) Stormwater management facilities map. The following information, illustrated on a map of the same scale as the topographic base map, shall be included:
  - (a) Total area to be paved or built upon, proposed surface contours, land area to be occupied by the stormwater management facilities and the type of vegetation thereon, and details of the proposed plan to control and dispose of stormwater.
  - (b) Details of all stormwater management facility designs, during and after construction, including discharge provisions, discharge capacity for each outlet at different levels of detention and emergency spillway provisions with maximum discharge capacity of each spillway.
- (6) Calculations.

- (a) Comprehensive hydrologic and hydraulic design calculations for the predevelopment and postdevelopment conditions for the design storms specified in § 300-26.
- (b) When the proposed stormwater management control measure (e.g., infiltration basins) depends on the hydrologic properties of soils, then a soils report shall be submitted. The soils report shall be based on on-site boring logs or soil pit profiles. The number and location of required soil borings or soil pits shall be determined based on what is needed to determine the suitability and distribution of soils present at the location of the control measure.

(7) Maintenance and repair plan. The design and planning of the stormwater management facility shall meet the maintenance requirements of § 300-32.

(8) Waiver from submission requirements. The municipal official or board reviewing an application under this article may, in consultation with the municipal engineer, waive submission of any of the requirements in § 300-31C(1) through (6) of this article when it can be demonstrated that the information requested is impossible to obtain or it would create a hardship on the applicant to obtain and its absence will not materially affect the review process.

(9) Site plan checklist. Major development applications shall require the applicant to complete and submit a copy of the site conditions checklist, which can be found immediately following this section.<sup>1</sup>

### **§ 300-32. Maintenance and repair.**

- A. Applicability. Projects subject to review as in § 300-23C shall comply with the requirements of Subsections B and C.
- B. General maintenance.
  - (1) The design engineer shall prepare a maintenance plan for the stormwater management measures incorporated into the design of a major development.
  - (2) The maintenance plan shall contain specific preventative maintenance tasks and schedules; cost estimates, including estimated cost of sediment, debris, or trash removal; and the name, address, and telephone number of the person or persons responsible for preventative and corrective maintenance (including replacement). Maintenance guidelines for stormwater management measures are available in the New Jersey Stormwater Best Management Practices Manual. The plan shall contain information on BMP location, design, ownership, maintenance tasks and frequencies, and other details as specified in Chapter 8 of the New Jersey BMP Manual, as well as the tasks specific to the type of BMP, as described in the applicable chapter containing design

---

1. Editor's Note: Said checklist is located at the end of this chapter.

specifics. **[Amended 2-10-2021 by Ord. No. 4-21]**

- (3) If the maintenance plan identifies a person other than the property owner (for example, a developer, a public agency or homeowners' association) as having the responsibility for maintenance, the plan shall include documentation of such person's or entity's agreement to assume this responsibility, or of the owner's obligation to dedicate a stormwater management facility to such person under an applicable ordinance or regulation. **[Amended 2-10-2021 by Ord. No. 4-21]**
- (4) Responsibility for maintenance shall not be assigned or transferred to the owner or tenant of an individual property in a residential development or project, unless such owner or tenant owns or leases the entire residential development or project. The individual property owner may be assigned incidental tasks, such as weeding of a green infrastructure BMP, provided the individual agrees to assume these tasks; however, the individual cannot be legally responsible for all of the maintenance required. **[Amended 2-10-2021 by Ord. No. 4-21]**
- (5) If the person responsible for maintenance identified under Subsection B(3) above is not a public agency, the maintenance plan and any future revisions based on Subsection B(7) below shall be recorded upon the deed of record for each property on which the maintenance described in the maintenance plan must be undertaken. **[Amended 2-10-2021 by Ord. No. 4-21]**
- (6) Preventative and corrective maintenance shall be performed to maintain the function of the stormwater management measure, including repairs or replacement to the structure; removal of sediment, debris, or trash; restoration of eroded areas; snow and ice removal; fence repair or replacement; restoration of vegetation; and repair or replacement of nonvegetated linings. **[Amended 2-10-2021 by Ord. No. 4-21]**
- (7) The party responsible for maintenance identified under Subsection B(3) above shall perform all of the following requirements: **[Amended 2-10-2021 by Ord. No. 4-21]**
  - (a) Maintain a detailed log of all preventative and corrective maintenance for the structural stormwater management measures incorporated into the design of the development, including a record of all inspections and copies of all maintenance-related work orders;
  - (b) Evaluate the effectiveness of the maintenance plan at least once per year and adjust the plan and the deed as needed; and
  - (c) Retain and make available, upon request by any public entity with administrative, health, environmental, or safety authority over the site, the maintenance plan and the documentation required by Subsection B(6) and (7) above.
- (8) The person responsible for maintenance identified under Subsection B(3)

above shall evaluate the effectiveness of the maintenance plan at least once per year and adjust the plan and the deed, as needed, and submit such changes for approval by the City Engineer. **[Amended 2-10-2021 by Ord. No. 4-21]**

- (9) The person responsible for maintenance identified under Subsection B(3) above shall retain and make available, upon request by any public entity with administrative, health, environmental, or safety authority over the site, the maintenance plan and the documentation required by Subsection B(7) and (8) within 10 days of such a request. **[Amended 2-10-2021 by Ord. No. 4-21]**
- (10) The requirements of § 300-32B(3) and (4) do not apply to stormwater management facilities that are dedicated to and accepted by the municipality or another governmental agency, subject to all applicable municipal stormwater general permit conditions, as issued by the Department. **[Amended 2-10-2021 by Ord. No. 4-21]**
- (11) In the event that the stormwater management facility becomes a danger to public safety or public health, or if it is in need of maintenance or repair, the municipality shall so notify the responsible person in writing. Upon receipt of that notice, the responsible person shall have 14 days to effect maintenance and repair of the facility in a manner that is approved by the Municipal Engineer or his designee. The municipality, in its discretion, may extend the time allowed for effecting maintenance and repair for good cause. If the responsible person fails or refuses to perform such maintenance and repair, the municipality or county may immediately proceed to do so and shall bill the cost thereof to the responsible person. **[Added 2-10-2021 by Ord. No. 4-21]**

- C. Nothing in this section shall preclude the municipality in which the major development is located from requiring the posting of a performance or maintenance guarantee in accordance with N.J.S.A. 40:55D-53.

#### **§ 300-33. Violations and penalties.**

- A. Any person who erects, constructs, alters, repairs, converts, maintains, or uses any building, structure, or land in violation of this article shall be subject to the following penalties.
- B. Failure to comply with any provisions of this article shall be considered a violation of the Coded Ordinances of Long Branch City and shall be punishable by a fine of \$1,000 or 90 days in jail, or both. Each day of such violation's continuance shall be considered as a separate offense and shall be separately punishable. These penalties shall not be the exclusive remedy available, and nothing in this article shall prevent an applicant from obtaining injunctive relief.

#### **§ 300-34. Effective date.**

This article shall take effect immediately upon the approval by the county review agency, or 60 days from the receipt of the article by the county review agency if the county review agency should fail to act.

**§ 300-35. Severability.**

If the provisions of any section, subsection, paragraph, subdivision, or clause of this article shall be judged invalid by a court of competent jurisdiction, such order of judgment shall not affect or invalidate the remainder of any section, subsection, paragraph, subdivision, or clause of this article.

**§ 300-36. Fees.**

All subdivision and site plan review fees associated with this article shall be provided by the applicant as adopted by the City of Long Branch within section § 69-29, Fees of this Code.